



- Tank has Overfill Protection – Slam Valve or Audible Warning (Audible over Truck Filling Tank)
- Tank has Vehicle Impact Protection if within 15 feet of vehicle traffic – bollards per IFC Specification
- No Smoking Signs on all visible sides
- Combustible Liquid Sign or NFPA 704 Marking on all visible sides
- 2A10BC Fire Extinguisher in outdoor cabinet located a maximum 25 feet away