



Puget Sound Fire Department FDC and PIV Standard



Through Wall Design

Freestanding Design

PIV

All new construction and or System Changes must comply with 5" Standard

- 5" FDC with 30-degree elbow
 - Locking Knox Cap
 - Painted Red with white letters identifying building serviced
- FDC must be located within 50' of a Fire Hydrant and located on same side of street

All FDC and PIV shall have 36" clearance around unit



Older 2 ½ inch FDC must have locking Knox Caps